

Guiseley Way, Durham Lane Industrial Park, Eaglescliffe, Stockton-On-Tees. TS16 0RF United Kingdom

Tel: +44 (0)1642 617406 Fax: +44 (0)1642 614178

E-mail: enquiries@carroll-meynell.com

www.carroll-meynell.com

## WALL MOUNTING ISOLATING TRANSFORMER **INSTALLATION AND SAFETY INSTRUCTIONS**

Manufactured to BSEN 61558 CM5000/WM0

- Read all of these instructions before you use the transformer
- These transformers are designed to provide mains isolation and reduce the mains voltage to a lower, safer value 2.
- Check the transformer case, plug and cable for signs of damage before use. Do not use if any damage is discovered
- Check the transformer rating against the power usage of the equipment you are going to use
- These transformers are rated for intermittent operation at their maximum listed power capability for a duty cycle of 25%. i.e. 5 minutes "ON" 15 minutes "OFF".
- These transformers may be used in a continuous operation mode at a rating of 50% of their maximum capability. e.g. a 5.0kVA unit may be operated continuously at 2.5kVA
- During normal operation these units will become warm. Ensure the transformer will not damage any floor covering it is standing on. It is not advisable to stand the unit on carpets, vinyl floor covering etc
- This unit is fitted with a thermal trip device to protect against overload and short circuit
- In the event of a short circuit to the output remove the cause of the fault before pressing the reset button on the thermal trip
- 10. In the event of an overload trip allow the unit to cool for at least 15 minutes before pressing the reset button
- 11. These units may be either hard wired to an electrical junction box or may be fitted with input leads and plugs. Units rated above 3.3kVA should not use 13A domestic plugs but be fitted with a suitably rated industrial style plug. The earth on the input plug must always be connected for complete safety to the output
- 12. These units are designed for the equipment they are to power to be hard wired to the internal terminals on the output of the transformer. The earth lead must be connected for complete safety.
- 13. The 110V output of the transformer has a centre tap that has been connected to the incoming earth lead giving a 55V - 0 - 55V supply. The centre tap connection has been made with a removable link so the unit can be converted to a straight 0 – 110V supply. When converting ensure the label is marked to indicate the conversion
- 14. Connection leads should be secured through the walls of the enclosure with cable glands to prevent damage
- 15. Secure the wall panels and the lid of the enclosure after wiring before using the unit
- 16. These units are Class 1 insulated and must not be tested on Portable Appliance Testers (PAT) as Class 2 double insulated products. Flash test only at 1.5KV between input and earth. DO NOT flash test output to earth
- 17. Transformers have an inherent high in-rush current at switch on. In the event of a supply fuse blowing check that the replacement is a suitably rated anti-surge type. Miniature Circuit Breakers (MCB's) protecting sockets should have a type C or D tripping characteristic
- 18. These units are protected against the ingress of solid and liquid contaminants to IP22 and are not designated for outdoor installation.
- 19. In the event of connecting an input lead/plug adopt the following wiring convention

Live Brown Wire Neutral Blue Wire

Green / Yellow Wire Earth

Ensure that such wiring is carried out by suitably qualified personnel





Guiseley Way, Durham Lane Industrial Park, Eaglescliffe, Stockton-On-Tees. TS16 0RF United Kingdom

Tel: +44 (0)1642 617406 Fax: +44 (0)1642 614178

E-mail: enquiries@carroll-meynell.com

www.carroll-meynell.com

## EC DECLARATION OF CONFORMITY C

Carroll & Meynell declare its sole responsibility for model: CM5000/WM0 single phase isolation transformer meets the basic safety requirements of European directives

- 1. Low Voltage Directive 2014/35/EU
- 2. REACH Regulation (EC) No 1907/2006
- 3. RoHS Restriction of Hazardous Substances Directive 2011/65/EU
- Waste Electrical and Electronic Equipment Directive 2012/19/EU

and any amendments.

The conformity assessment is based on the following harmonised standards

BS EN 61558

Country of Origin - United Kingdom

Name: Karen Shovelin

Title: Quality health & Safety Manager

Signature: Karen Shovelin

Date: 15/08/2019

On behalf of CARROLL & MEYNELL Transformers Limited

